



Notified Body nr. 0370

CERTIFICATE



No.

0370-CPR-0672

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT CONTROL VENTILATORS (FANS)
PRODUCT RANGE **TJHT F400₁₂₀**

Produced by:

SOLER Y PALAU SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4
08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

17/32301811 (EUROPE) & 17/32301816 (EUROPE)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 12101-3:2015

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 28th November 2008 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 24th November 2017.

The monitoring assessment will be done before November 2018

Bellaterra, 24th November 2017

 Applus⁺

LGAI Technological Center, S.A.
Jordi Brufau Redondo
General Manager

 Applus⁺

LGAI Technological Center, S.A.
Xavier Ruiz Peña
Product Conformity B.U., Managing Director



This document is not valid without its technical annex, whose number coincides with the number of certificate.