



Notified Body No. 0370

CERTIFICATE



No. **0370-CPR-0955**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation *305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT CONTROL VENTILATORS (FANS)
PRODUCT RANGE: **CHGT F300**

Place on the market under the name of:

S&P SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4
08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

18/32301533 (EUROPE) & 18/32301534 (EUROPE) & 18/32301535 (EUROPE)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


EN 12101-3:2015

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 20th March 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 17th December 2018.

The monitoring assessment will be done before November 2019

Bellaterra, 17th December 2018


Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex, whose number coincides with the number of certificate.

TECHNICAL ANNEX 0370-CPR-0955

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1.- Application:

- Extractor tested inside the furnace.
- Extractor F300 (60). Tested during 120 min.
- Dual use.

2.- Characteristics:

- Motor: WEG
- Rated Voltage motor: 400 V.

3.- Accessories:

- Acoustic panel made of glass wool reference "Panel Intraver Neto-25" from Isover of 25 mm in thickness and 25 kg/m3.
- Flexible connection made of flexible Fiberglass impregnated with polyurethane reference "ACOP RECT CHGT/CGT F400".
- Back draft shutter CLAR made of galvanized Steel sheet.
- Louvre back draft shutter PER-CR made of aluminum and steel sheet.
- Isolators reference "FProtect" F400" from Gave.

The complete technical data of the certified range **CHGT F300** are detailed in the technical file and the range report nº 14/7966-1784.

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay - Opening under wind load within a given time; - Opening under snow load within a given time.	4.1.1	NA
		NA
Operational reliability - Application categories; - Motor rating.	4.2.2	<ul style="list-style-type: none"> • Thermally uninsulated • Installation inside and outside smoke reservoir. • Direct feed • Dual purpose use
	4.2.3	NPD
Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test.	4.3.2	+/-20% (P _s)
Resistance to fire	4.4	F300(60)
Ability to open under environmental conditions - Opening under wind load within a given time; - Opening under snow load within a given time.	4.5	NA
		NA
Durability of operational reliability	4.6	NPD

PASS; NPD = No Performance Determined; NA = Not Applicable

