LGAI Technological Center, S.A. (APPLUS)
Campus UAB - Ronda de la Font del Carme s/n
08193 Bellaterra (Barcelona)
T +34 93 567 20 00
F +34 93 567 20 01
www.applus.com





# **CERTIFICATE**



No

0370-CPR-0741

### CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3: SPECIFICATION FOR POWERED SMOKE AND HEAT

CONTROL VENTILATORS (FANS)
PRODUCT RANGE: **THGT/2 F400**<sub>120</sub>

Place on the market under the name of:

# S&P SISTEMAS DE VENTILACIÓN, S.L.U.

C/ LLEVANT, 4 08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

18/32301533 (EUROPE) & 18/32301534 (EUROPE)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 28<sup>th</sup> November 2008 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 17<sup>th</sup> December 2018.

The monitoring assessment will be done before November 2019

Bellaterra, 17th December 2018

LISTE TECHNOLOGICAL CENTER, S.A.

Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

This document is not valid without its technical annex, whose number coincides with the number of certificate.

#### **LGAI**

LGAI Technological Center, S.A. (APPLUS)
Campus UAB s/n – Ronda de la Font del Carme, s/n
E - 08193 Bellaterra (Barcelona)
T +34 93 567 20 00
F +34 93 567 20 01
www.appluslaboratories.com



Technical Annex Ed. 4 19/05/2018

#### TECHNICAL ANNEX 0370-CPR-0741

## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

#### 1.- Application:

- Extractor tested inside the furnace.
- Extractor F400 (120).
- Dual use.

#### 2.- Characteristics:

Motor: WEG and Leroy SomerRated Voltage motor: 400 V.

The complete technical data of the certified range **THGT/2 F400**<sub>120</sub> are detailed in the technical file and the range report no 08/32311847.

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay - Opening under wind load within a given time; - Opening under snow load within a given time.	4.1.1	NA
	4.1.1	NA
Operational reliability - Application categories; - Motor rating.	4.2.2	<ul><li>Thermally uninsulated</li><li>Direct feed</li><li>Dual purpose use</li></ul>
	4.2.3	NPD
Effectiveness of smoke/hot gas extraction: - Gas flow and pressure maintenance during smoke and heat extraction test.	4.3.2	+/-20% (P <sub>S</sub> )
Resistance to fire	4.4	F400(120)
Ability to open under environmental conditions - Opening under wind load within a given time; - Opening under snow load within a given time.	4.5	NA
		NA
Durability of operational reliability	4.6	NPD

PASS; NPD = No Performance Determined; NA = Not Applicable

