

**CERTIFICATE OF ANALYSIS****CERTIFICATE NO.**

1015447.5H

**CUSTOMER**AFS BORU SANAYI A.Ş  
Ivedik Organize Sanayi Bölgesi  
1468. Cadde No:153 Ostim / ANKARA  
TURKEY**CUSTOMER REF.****SAMPLE DETAILS**

Aluminium Flexible Air Duct

**DATE RECEIVED**

08-Feb-11

**METHOD: (Determination of Susceptibility of Materials to Fungal growth using ASTM G21)****DATE ANALYSED**

06-Mar-11

**DATE REPORTED**

14-Apr-11

SAMPLE	Growth Rating
IMSL Reference (Filter Paper)	4.0
ALUAFS.F HYGIENE GREEN	0.0

**Inoculum:**

<i>Aspergillus niger</i>	ATCC 9642
<i>Paecilomyces variotti</i>	ATCC 18502
<i>Chaetomium globosum</i>	ATCC 6205
<i>Gliocladium virens</i>	ATCC 9645
<i>Aureobasidium pullulans</i>	ATCC 15233

**Key:**

- 0 No growth apparent under magnification
- 1 Traces of growth (less than 10%)
- 2 Light growth (10 - 30%)
- 3 Medium growth (30 - 60%)
- 4 Heavy Growth (60% to complete coverage)

INDUSTRIAL MICROBIOLOGICAL SERVICES LTD  
PALE LANE  
HARTLEY WINTNEY  
HANTS  
RG27 8DH  
UKKYLE ALLISON  
STUDY DIRECTOR