

**CERTIFICATE OF ANALYSIS** **CERTIFICATE NO.** 1015172.11

**CUSTOMER** **CUSTOMER REF.**  
 AFS BORU SANAYI A.Ş  
 Ivedik Organize Sanayi Bölgesi  
 1468. Cadde No:153 Ostim / ANKARA  
 TURKEY

**SAMPLE DETAILS** **DATE RECEIVED** 30-Nov-10  
 Aluminium Flexible Air Duct

**METHOD: (Determination of Antibacterial Activity using ISO 22196)**

**DATE ANALYSED** 15-Dec-10 **DATE REPORTED** 17-Dec-10

**RESULTS (AS CFU CM -2)**

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	<i>Staph aureus</i>	1.6E+04	1.0E+04	-	-
ISOAFS-ALU HYGIENE GREEN	<i>Staph aureus</i>	1.6E+04	< 1.0	≥ 4.2	≥ 99.99%

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD  
 PALE LANE  
 HARTLEY WINTNEY  
 HANTS  
 RG27 8DH  
 UK

PETER D ASKEW  
 MANAGING DIRECTOR

