

CERTIFICATE OF ANALYSIS

CERTIFICATE NO. 1015447.21

CUSTOMER

CUSTOMER REF.

AFS BORU SANAYI A.Ş
 İvedik Organize Sanayi Bölgesi
 1468. Cadde No:153 Ostim / ANKARA
 TURKEY

SAMPLE DETAILS

DATE RECEIVED 08-Feb-11

Aluminium Flexible Air Duct

METHOD: (Determination of Antibacterial Activity using ISO 22196)

DATE ANALYSED 07-Mar-11

DATE REPORTED 22-Mar-11

RESULTS (AS CFU CM -2)

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	<i>Ps. aeruginosa</i>	1.8E+04	5.2E+04	-	-
ISOAFS-ALU HYGIENE GREEN	<i>Ps. aeruginosa</i>	1.8E+04	≤ 1.00	≥ 4.3	≥ 99.99%

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD
 PALE LANE
 HARTLEY WINTNEY
 HANTS
 RG27 8DH
 UK

PETER D ASKEW
 MANAGING DIRECTOR



Industrial Microbiological Services Ltd Registered in England No 3264423 Registered Office The Oldfellows Hall Oxford Road Reading Berkshire RG1 7NG