

CERTIFICATE OF ANALYSIS

CERTIFICATE NO. 1015447.1E

CUSTOMER

AFS BORU SANAYI A.Ş
 İvedik Organize Sanayi Bölgesi
 1468. Cadde No:153 Ostim / ANKARA
 TURKEY

CUSTOMER REF.

SAMPLE DETAILS

Aluminium Flexible Air Duct

DATE RECEIVED

08-Feb-11

METHOD: (Determination of Antibacterial Activity using ISO 22196)

DATE ANALYSED

07-Mar-11

DATE REPORTED

22-Mar-11

RESULTS (AS CFU CM -2)

| SAMPLE | | CONTACT TIME | | LOG REDUCTION | % DIFFERENCE |
|----------------------|----------------|--------------|---------|---------------|--------------|
| | | 0 | 24 | | |
| IMSL Reference (PS) | <i>E. coli</i> | 1.4E+04 | 2.7E+05 | - | - |
| ISOAFS-ALU.F HYGIENE | <i>E. coli</i> | 1.4E+04 | ≤ 1.00 | ≥ 4.1 | ≥ 99.99% |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD
 PALE LANE
 HARTLEY WINTNEY
 HANTS
 RG27 8DH
 UK

PETER D ASKEW
 MANAGING DIRECTOR



Industrial Microbiological Service Ltd Registered in England No 3264423. Office The Oddfellows Hall Oxford Road Reading Berkshire RG1 7NG