

**CERTIFICATE OF ANALYSIS**

**CERTIFICATE NO.** 1015447.4E

**CUSTOMER**

AFS BORU SANAYI A.Ş  
 Ivedik Organize Sanayi Bölgesi  
 1468. Cadde No:153 Ostim / ANKARA  
 TURKEY

**CUSTOMER REF.**

**SAMPLE DETAILS**

Aluminium Flexible Air Duct

**DATE RECEIVED**

08-Feb-11

**METHOD: (Determination of Antibacterial Activity using ISO 22196)**

**DATE ANALYSED**

07-Jun-11

**DATE REPORTED**

12-Jul-11

**RESULTS (AS CFU CM -2)**

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	<i>Legionella</i>	7.4E+04	3.7E+03	-	-
ISOAFS-ALU.F HYGIENE	<i>Legionella</i>	7.4E+04	≤ 1.00	≥ 4.87	≥ 99.99%

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD  
 PALE LANE  
 HARTLEY WINTNEY  
 HANTS  
 RG27 8DH  
 UK

PETER D ASKEW  
 MANAGING DIRECTOR



Industrial Microbiological Services Ltd Registered in England No 3264423 Registered Office The Oddfellows Hall Oxford Road Reading Berkshire RG1 7NG