

CERTIFICATE OF ANALYSIS

CERTIFICATE NO.

1015447.5E

CUSTOMER

CUSTOMER REF.

AFS BORU SANAYI A.Ş
 İvedik Organize Sanayi Bölgesi
 1468. Cadde No:153 Ostim / ANKARA
 TURKEY

SAMPLE DETAILS

DATE RECEIVED

08-Feb-11

Aluminium Flexible Air Duct

METHOD: (Determination of Susceptibility of Materials to Fungal growth using ASTM G21

DATE ANALYSED

06-Mar-11

DATE REPORTED

14-Apr-11

SAMPLE	Growth Rating
IMSL Reference (Filter Paper)	4.0
ISOAFS-ALU.F HYGIENE	0.0

Inoculum:

- | | |
|--------------------------------|------------|
| <i>Aspergillus niger</i> | ATCC 9642 |
| <i>Paecilomyces variotti</i> | ATCC 18502 |
| <i>Chaetomium globosum</i> | ATCC 6205 |
| <i>Gliocladium virens</i> | ATCC 9645 |
| <i>Aureobasidium pullulans</i> | ATCC 15233 |

Key:

- 0 No growth apparent under magnification
- 1 Traces of growth (less than 10%)
- 2 Light growth (10 - 30%)
- 3 Medium growth (30 - 60%)
- 4 Heavy Growth (60% to complete coverage)

INDUSTRIAL MICROBIOLOGICAL SERVICES LTD
 PALE LANE
 HARTLEY WINTNEY
 HANTS
 RG27 8DH
 UK



KYLE ALLISON
 STUDY DIRECTOR

A handwritten signature in black ink, appearing to read 'K. Allison'.