

INDUSTRIAL MICROBIOLOGICAL SERVICES LTD

CERTIFICATE OF ANALYSIS

CERTIFICATE NO.

1015447.4J

CUSTOMER

CUSTOMER REF.

AFS BORU SANAYI A.Ş Ivedik Organize Sanayi Bölgesi 1468. Cadde No:153 Ostim / ANKARA **TURKEY**

SAMPLE DETAILS

DATE RECEIVED

08-Feb-11

Aluminium Flexible Air Duct

METHOD: (Determination of Antibacterial Activity using ISO 22196)

DATE ANALYSED

07-Jun-11

DATE REPORTED

12-Jul-11

RESULTS (AS CFU CM -2)

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	Legionella	7.4E+04	3.7E+03	-	-
ISOAFS-ALU.F HYGIENE GREEN	Legionella	7.4E+04	≤ 1.00	≥ 4.87	≥ 99.99%
		-			

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD

PALE LANE

HARTLEY WINTNEY

HANTS

RG27 8DH

UK

PETER D ASKEW MANAGING DIRECTOR

CERTIFIED

AS A GENUINE DOCUMENT ISSUED BY INDUSTRIAL MICROBIOLOGICAL SERVICES LTD

REGISTERED IN ENGLAND NO 3264423

Ltd Registered in Elighand No 3,044 & Registered Industrial Microbiological 8

Hall Oxford Road Reading Berkshire RG1 7NG

DATED

27MAR 2012