

CERTIFICATE OF ANALYSIS**CERTIFICATE NO.**

1015447.5J

CUSTOMER

AFS BORU SANAYI A.Ş
Ivedik Organize Sanayi Bölgesi
1468. Cadde No:153 Ostim / ANKARA
TURKEY

CUSTOMER REF.**SAMPLE DETAILS**

Aluminium Flexible Air Duct

DATE RECEIVED

08-Feb-11

METHOD: (Determination of Susceptibility of Materials to Fungal growth using ASTM G21)**DATE ANALYSED**

06-Mar-11

DATE REPORTED

14-Apr-11

SAMPLE	Growth Rating
IMSL Reference (Filter Paper)	4.0
ISOAFS-ALU.F HYGIENE GREEN	0.0

Inoculum:

<i>Aspergillus niger</i>	ATCC 9642
<i>Paecilomyces variotti</i>	ATCC 18502
<i>Chaetomium globosum</i>	ATCC 6205
<i>Gliocladium virens</i>	ATCC 9645
<i>Aureobasidium pullulans</i>	ATCC 15233

Key:

- 0 No growth apparent under magnification
- 1 Traces of growth (less than 10%)
- 2 Light growth (10 - 30%)
- 3 Medium growth (30 - 60%)
- 4 Heavy Growth (60% to complete coverage)

INDUSTRIAL MICROBIOLOGICAL SERVICES LTD
PALE LANE
HARTLEY WINTNEY
HANTS
RG27 8DH
UK



KYLE ALLISON
STUDY DIRECTOR