

**CERTIFICATE OF ANALYSIS**

**CERTIFICATE NO.**

1015172.1K

**CUSTOMER**

**CUSTOMER REF.**

AFS BORU SANAYI A.Ş  
 Ivedik Organize Sanayi Bölgesi  
 1468. Cadde No:153 Ostim / ANKARA  
 TURKEY

**SAMPLE DETAILS**

Aluminium Flexible Air Duct

**DATE RECEIVED**

30-Nov-10

**METHOD: (Determination of Antibacterial Activity using ISO 22196)**

**DATE ANALYSED**

15-Dec-10

**DATE REPORTED**

17-Dec-10


**RESULTS (AS CFU CM -2)**

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	<i>Staph aureus</i>	1.6E+04	1.0E+04	-	-
SONOAFS-ALU HYGIENE GREEN	<i>Staph aureus</i>	1.6E+04	< 1.0	≥ 4.2	≥ 99.99%

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD  
 PALE LANE  
 HARTLEY WINTNEY  
 HANTS  
 RG27 8DH  
 UK



PETER D ASKEW  
 MANAGING DIRECTOR