

**CERTIFICATE OF ANALYSIS**

**CERTIFICATE NO.**

1015447.5K

**CUSTOMER**

**CUSTOMER REF.**

AFS BORU SANAYI A.Ş  
Ivedik Organize Sanayi Bölgesi  
1468. Cadde No:153 Ostim / ANKARA  
TURKEY

**SAMPLE DETAILS**

**DATE RECEIVED**

08-Feb-11

Aluminium Flexible Air Duct

**METHOD: (Determination of Susceptibility of Materials to Fungal growth using ASTM G21)**

**DATE ANALYSED**

06-Mar-11

**DATE REPORTED**

14-Apr-11

| SAMPLE                        | Growth Rating |
|-------------------------------|---------------|
| IMSL Reference (Filter Paper) | 4.0           |
| SONOAFS-ALU HYGIENE GREEN     | 0.0           |

Inoculum:

|                                |            |
|--------------------------------|------------|
| <i>Aspergillus niger</i>       | ATCC 9642  |
| <i>Paecilomyces variotti</i>   | ATCC 18502 |
| <i>Chaetomium globosum</i>     | ATCC 6205  |
| <i>Gliocladium virens</i>      | ATCC 9645  |
| <i>Aureobasidium pullulans</i> | ATCC 15233 |

Key:

- 0 No growth apparent under magnification
- 1 Traces of growth (less than 10%)
- 2 Light growth (10 - 30%)
- 3 Medium growth (30 - 60%)
- 4 Heavy Growth (60% to complete coverage)

INDUSTRIAL MICROBIOLOGICAL SERVICES LTD  
PALE LANE  
HARTLEY WINTNEY  
HANTS  
RG27 8DH  
UK



KYLE ALLISON  
STUDY DIRECTOR