

CERTIFICATE OF ANALYSIS

CERTIFICATE NO. 1015447.2F

CUSTOMER

AFS BORU SANAYI A.Ş
 Ivedik Organize Sanayi Bölgesi
 1468. Cadde No:153 Ostim / ANKARA
 TURKEY

CUSTOMER REF.

SAMPLE DETAILS

Aluminium Flexible Air Duct

DATE RECEIVED 08-Feb-11

METHOD: (Determination of Antibacterial Activity using ISO 22196)

DATE ANALYSED 07-Mar-11

DATE REPORTED 22-Mar-11

RESULTS (AS CFU CM -2)

SAMPLE		CONTACT TIME		LOG REDUCTION	% DIFFERENCE
		0	24		
IMSL Reference (PS)	<i>Ps. aeruginosa</i>	1.8E+04	5.2E+04	-	-
SONOAFS-ALU.F HYGIENE	<i>Ps. aeruginosa</i>	1.8E+04	≤ 1.00	≥ 4.3	≥ 99.99%

The above data shows the difference in the population following contact with the surface of the samples listed for 24 hours at 35°C under a RH of > 95% relative to the initial population.

NS = Poor survival on control supplied.

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD
 PALE LANE
 HARTLEY WINTNEY
 HANTS
 RG27 8DH
 UK

PETER D ASKEW
 MANAGING DIRECTOR



Industrial Microbiological Services Ltd Registered in England No: 3264423 Registered Office The Oddfellows Hall Oxford Road Reading Berkshire RG1 7NG