

CERTIFICATE OF COMPLIANCE

Certificate Number 20171101-MH61932
Report Reference MH61932-20171031
Issue Date 2017-NOVEMBER-01

Issued to: AFS BORU SANAYI A S
Ivedik O S B
1468 Cad Eski 24 Cad No 153
06370 Ostim Ankara TURKEY

**This is to certify that
representative samples of**

AIR DUCTS

Class 1, flexible; Sizes 2 through 18 in., designated as "ISOAFS-ALU UL". Duct sizes 2, 2.6., 3.23, 4, 5, 6, 7, 8, 9, 10, 12, 14, 16 and 18 in. ID. The air ducts consist of a spirally wound wire, encapsulated in a core liner material, covered with fiberglass blanket material and an exterior vapor barrier material.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 181, Factory Made Air Ducts and Air Connectors
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

