



Declaration of Conformity

Registration No : 081013 AFSDOC.01

Issue Date : October 8, 2013

ISOAFS-PVC.M1

Insulated PVC flexible air duct

was tested pursuant to applicable test procedures

and complies with the requirements of

EN 13180: 2001

TS EN 13180: 2006

Manufacturer : **AFS BORU SANAYI A.S.**

Ivedik O.S.B. 1468 Cad. No:153 Ostim 06370 Ankara / Turkey

Diameter Range : \varnothing 102 mm – \varnothing 305 mm

Test Results : Diameter class : B

Air tightness class : C

Positive rated pressure : 3000 Pa (for all diameters)

Negative rated pressure : - 1400 Pa (\varnothing 102 mm), - 850 Pa (\varnothing 127 mm),

- 500 Pa (\varnothing 152 mm), - 250 Pa (\varnothing 254 mm),

- 175 Pa (\varnothing 305 mm)

Minimum bending radius : 0.5 D

Sag : 7° to 14°

Crushing strength : compressed 12 to 20 kg. and uncompr. 0,5 to 1,5 kg.

Authorized by : _____

Zahid Poyraz

General Coordinator