



# *Classification of Reaction to Fire Performance According to EN 13501-1:2007*

Registration No: 161118.CER.03

**Issue Date: November 16, 2018**

**Manufacturer** : **AFS BORU SANAYI A.S.**  
Ivedik O.S.B. 1468. Cad. No: 153 Ostim 06370 Ankara /  
Turkey

**Product Name** : SEMIAFS.INOX

**Product Description** : Semi flexible air duct comprising 1 layer 316 L stainless  
steel secured using an interlock system

This certificate reports the classification assigned to SEMIAFS-INOX in line with  
the procedures given in EN 13501-1:2007.

## **Reaction to fire classification: A1**

Authorized by :

Betül Başkaya  
Laboratory Manager

Ali Akyön  
Technical Advisor