



Classification of Reaction to Fire Performance According to EN 13501-1:2007

Registration No: 161118.CER.02

Issue Date: November 16, 2018

Manufacturer : **AFS BORU SANAYI A.S.**
Ivedik O.S.B. 1468. Cad. No: 153 Ostim 06370 Ankara /
Turkey

Product Name : SEMIAFS.C

Product Description : Semi flexible air duct comprising 1 layer aluminium
secured using an interlock system

This certificate reports the classification assigned to SEMIAFS.C in line with the
procedures given in EN 13501-1:2007.

Reaction to fire classification: A1

Authorized by :

Betül Başkaya
Laboratory Manager

Ali Akyön
Technical Advisor