

CERTIFICATE OF COMPLIANCE

Certificate Number R40061
Report Reference R40061-20191124
Issue Date 2020-JANUARY-10

Issued to: AFS BORU SANAYI A S
Ivedik O S B
1468 Cad Eski 24 Cad No 153
06370 Ostim Ankara TURKEY

This certificate confirms that representative samples of AIR DUCT VIBRATION ISOLATION CONNECTORS
See addendum for models.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: NFPA 701-2019, "Fire Test for Flame-Resistant Textile and Films" Test Method 1

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R40061
Report Reference R40061-20191124
Issue Date 2020-JANUARY-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

The products covered are flexible duct connectors identified as Air Duct Vibration Isolation Connectors with coated silicone fabric, designated as AFSCONNECTOR.SILICONE UL, Air Duct Vibration Isolation Connectors with Neoprene coated fabric, designated as AFSCONNECTOR.NEOPRENE UL and Air Duct Vibration Isolation Connectors with PVC coated fabric, designated as AFSCONNECTOR.PVC UL. The finished connectors have steel width ranges in between 60 mm and 150 mm (depending on customer's requirements) and a maximum fabric width of 150 mm.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

